



NATIONAL INSTITUTE OF PUBLIC HEALTH

DEPARTMENT OF ENVIRONMENTAL HYGIENE

Chocimska Street 24 00-791 Warsaw ; Phone (22) 5421354; Fax (22) 5421287; e-mail:sek-zhk@pzh.gov.pl

HYGIENIC ATTEST: HK/W/0644/01/2013

Product: **Compound ZINGA**

Containing: **mocronised zinc**

Destined for: **ant-corrosion protection of steel surfaces, including inner surfaces of steel tanks designed to store potable water for people**

The above mentioned product is acceptable according to hygienic criteria with the following conditions:

The compound destined for professional use. Each container covered with the compound must be painstakingly washed with water.

There must be a label in Polish on the packaging, which should include recommendations concerning precautions – as in Safety Data Sheet of the product, in accordance with the proper law regulations.

The product should be kept out of children's reach.

Producer: Zingametall b.v.b.a.
B-9810 Eke
Rozenstraat 4, Belgium

This certificate issued for:

ZINGAMETALL POLAND s.c.
Dionizy Wiśniewski, Mirosława Wiśniewska
87-100 Toruń, ul. Grudziądzka 151

The attest may be corrected or cancelled after receiving a proper proof by any side or in the case of changes made in composition or in technological production process.

The document's validity : 2018-10-10

Date of issue: 10 October 2013.

Kierownik
Zakładu Higieny Środowiska
B. Krogulska
dr Bożena Krogulska